


Test Verification of Conformity

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced standard and sections at the time the tests were carried out. This verification is part of the full test report(s) and should be read in conjunction with them.

Applicant Name & Address:	Panduit Corporation 6200 175th Street Tinley Park IL 60477 USA
Product Description:	Modular jack part numbers <ul style="list-style-type: none">• CJ6X88TG** and CJS6X88TG**• CJH6X88TG** and CJSH6X88TG** (shuttered)• CJK6X88TG** and CJSK6X88TG** (keyed)• CJUD6X88TG** (up/down wire caps)• CJLR6X88TG** (left/right wire caps)• NK6X88M** (Netkey, punchdown jacks) Field terminable plug part numbers <ul style="list-style-type: none">• FP6X88MTG• FPS6X88MTG
Test description:	Performance testing of connecting hardware endurance to the standard requirement of IEC 60512-99-002 for support of IEEE Std 802.3™ Type 4 remote powering applications
Standard used:	<i>IEC 60512-99-002 Connectors for electrical and electronic equipment – Tests and measurements – Part 99-002: Endurance test schedules – Test 99b: Test schedule for unmating under electrical load, Edition 2.0 dated January 2022</i>
Verification Issuing Office Name & Address:	Intertek Testing Services NA, Inc. 3933 US Route 11, Cortland, NY 13045
Test Report Number(s):	105659202CRT-001b, dated 18-December-2023 revised 25-April-2024



Signature

Name: Antoine Pelletier
Position: Project Engineer
Date: 25-April-2024

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.