



3933 US ROUTE 11, CORTLAND, NEW YORK 13045  
Phone Number: 1-800-345-3851 Fax Number: 607-758-3648

## REPORT OF TEST

Panduit Corporation  
10500 167th Street  
Orland Park, IL 60467


The products described in this Report were tested for compliance to the standard(s) listed below. The products listed below are not part of an Intertek Verification Program and the results are provided to the client as a one time performance test.

Reference Intertek Report No.: 101114174CRT-003

Date: March 26, 2013

### Test:

Electrical performance testing of a 4-connector channel configuration, as illustrated below, to the standard requirements of ANSI/TIA-568-C.2 for Category 6A channel.



Component Id	Manufacturer	Description	Part number
1	Panduit	Patch Cord	STP6X5MBU
2	Panduit	Outlet & Closet Hardware	CJS6X88TGY
3	Panduit	Zone Cord	SAJPBU5MBL
4	Panduit	Horizontal Solid Cable	PFP6X04
5	Panduit	Patch Cord	STP6X2MBU
6	Panduit	Patch Cord	STP6X3MBU


### Standard and sections used:

ANSI/TIA-568-C.2-2009: Balanced Twisted-Pair Telecommunications Cabling and Components Standards, dated August 2009 (Sections 6.2.1 to 6.2.19)

### Conclusion:

The channel cabling configuration, as described above, was tested in accordance with the ANSI/TIA-568-C.2 standard, and did comply with the indicated applicable transmission requirements. The channel was assembled by Intertek from samples that were submitted by the client. The testing was performed at Intertek located in Cortland, New York.

Reviewed and approved by:

  
John Cash  
Technician  
Global Cabling Products Testing

  
Antoine Pelletier  
Engineer  
Global Cabling Products Testing

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.